



TEST Reg. no. 300



**DANISH
TECHNOLOGICAL
INSTITUTE**

Teknologiparken
Kongsvang Allé 29
DK-8000 Aarhus C
Phone +45 72 20 10 00
Fax +45 72 20 10 19
Info@teknologisk.dk

Danish Technological Institute

Accredited Test Body, DANAK (Danish accreditation no. 300)

TEST CERTIFICATE III

Extract of report no.: **300-ELAB-2198**

Item: Biofuel boiler
Manufacturer: Biodom 27 d.o.o.
Model: Biodom 21
Requested by: BIODOM 27 d.o.o.
 OIC Hrpelje 14A, 6240 Kozina, Slovenia
 VAT nr. SI71987657

Procedure:

X	Testing according to EN 303-5:2012 with requirements according to Class 5
---	---

Safety requirements according to EN 303-5:2012 are fulfilled

TEST RESULTS


Stoking princ.: Automatic

Fuel: Biomass

Testing has been carried out with wood pellets (C1) with the following results:

Measurement	Unit	Result	Limit
Nominal heat output	kW	23	
CO at 10% O ₂	mg/m _n ³	44	500
OGC at 10% O ₂	mg/m _n ³	< 6	20
Dust at 10% O ₂	mg/m _n ³	25	40
Efficiency	%	91,6	88,4
Minimum heat output	kW	6,1	
Efficiency	%	91,0	87,8

Please note that the stated values are an extract from the test report. For further information please refer to the test report.

Aarhus, 3. March 2016  Anders Pødenphant B. Sc.	Chimney sweeper endorsement
---	-----------------------------

Based on the abovementioned particle emission it is hereby certified that the biofuel boiler fulfils the emission requirements in appendix 2 to declaration no. 1461 of 07/12/2015 regarding regulation of air pollution from solid fuel boilers below 1 MW. Furthermore it is certified that the boiler fulfils the efficiency requirement in the Danish Building Regulations.